

Clarifications to the queries raised in Prebid meeting on 20-01-2012 for Construction of Fastener Manufacturing Unit .

Contractor Present

- 1) M/s kwalky Construction Engineers
- 2) M/s Shri Infratech
- 3) M/s Sree Balaji construction
- 4) M/s Manjeera Construction.

S. No	Query	Item No in BOQ of Tender	Read as
1	Approved brand of TMT steel bars	10	Brands to be used at site – Dhanalakshmi, JayRaj, VSP, TISCO, SAIL etc
2	Cement for RCC, Masonry, Plastering etc	6,7,8 etc	L&T, Priya Gold, Srichakra, Birla, Sakthi, Ultratek etc grade 53.
3	PT beam	8(iii)	Read the item as <u>Post tensioning beam</u> and the work shall be carried by specialized agencies only.
4	Height of the floors	-----	1) Ground floor = 4.5mtr beam bottom 2) 2nd, 3rd & 4th = 3 to 3.5mtr beam bottom.
5	Providing & applying 2 coats of synthetic enamel paint on new wood/steel.	23	Please read the item(23) as providing & painting of on walls with 2 or 3 coats of O.B.D including luppum finish one coat and surface preparation
6	Please note that MIDHANI reserves the right to operate partial quantity or delete the item completely and no compensation will be paid for the contractor for deletion or partial operation of item.		

- 1) This will form the part of the tender
- 2) All other terms and conditions remain same as our earlier tender notification MDN/PROJ/CVL/12/Fastner Plant Civil works, dated 12-01-12.

Madan Mohan .G
D.G.M (Projects)